

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1496:146 Page 1 of 1

CATEGORY: Power Units

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100 Fax (718) 899-1932

DESIGN: Model FAL400UL-ADA Power-limited Indicating Circuit Power Supply Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. The standby batteries must provide 24 hours standby power during power loss. The battery circuit shall be fully supervised.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a power-limited indicating circuit power supply module for use with separately listed compatible fire alarm control units and indicating devices.

XLf: 7315-1335:101

12-09-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager